



WORK REPORT

Customer Name	Our Own English High School for Girls						ABAT-WTS-1696		
School Address:	Industrial Are (6) Al Sharjah								
Date Cleaning	23/10/2020		Next Cleaning Date	23/04/2021		Worked hours	9-10 hours		
Type of Building	*	Commercial		Residential		Other:			
Tank Location	*	Roof	*	Ground		Basement		Other	
Type of Tank		RCC		Size				Other	
		Concrete uncoated	*	Molded Fiber Glass		GRP Panel		Steel Panel	
		Concrete Coated		galvanized		Polyurethane		Other	
Quantity of Water				Full		Half	*	Empty	
Tank condition				Clean	*	Dirty		Very Dirty	
Bio-Film/Staining		Yes	*	No		Sediments	*	Yes	no
Mold		yes	*	No		Algae		Yes	* no
Lid / cover fitted	*	yes		no		damaged			
leaks		Yes	*	No	Where	Valve		Tank	pipe
Vent Screen Present		Yes		No	*			N/A	
Vent Screen installed		yes		No	*			N/A	
Pump Working	*	Yes		No		Valves Working	*	Yes	No
Pipes		Galvanized	*	UPVC		Copper		Tank Fitted With A Drain	* Yes No
Access: Yes									
Ladders Inside		Yes	*	No		LADDER OUTSIDE		Yes	* No
Pipes Disinfected		Yes		No	*			N/A	
Test Method				Result		Discharge		Correction Method	
	1	2	3	7.1		Yes	No	A	B
Legend:	1=Litmus Paper		2=Ph Test Kit		3= Photometer		A= Dilute With H2o		B= ADD Neutralizer
Comments: Satisfactory									
Recommendations For Improvement:									
Signed On Behalf Of Abat Environmental Services									
 									
Recommended Frequency Of Cleaning				Years	*	Every 6 Months		Other	
Photo Attached	*	Yes		No		Additional Information Attached	*	Yes	No

Certificate

We certify that the water tanks in **Our Own English High School for Girls**

Has been cleaned and disinfected according to the international standard and U.A.E rules.

We confirm and guarantee these tanks are free from....

- 1- Fungi, algae and bacteria.
- 2- Calcium Scales.
- 3- Sand and Precipitated materials.

This certificate is valid for six months starting from

23 Oct 2020 Till 23 Apr 2021.

It is your responsibility to clean the tank periodically according to Sharjah Municipality rules and whenever it is required.



APPROVED BY

AL BURJ ALTHAHABY

ENVIRONMENTAL SERVIC